

Approved Document 'M' BS8300 Accessible Toilet Checklist

Site or CompanyName

Date Inspected


Address

Are photographs available

Your details

Can we publish your details? Please circle YES or NO i want to remain anonymous

	YES	NO
Is the room at least 1500mm x2200mm		
Comments		
Does the door open outwards		
If not is the room larger		
Is there a horizontal grab rail on the inside of door		
Does the WC pan project 750mm from back wall		
Can a wheelchair back up to the wall for sideways transfer		
Are there any obstructions preventing this		
Is the tap on the corner of the washbasin nearest the WC		
Is the cistern flush lever positioned to the open side		
Is the WC height to top of seat 480mm		
Is there an alarm pull cord		
Is it accessible or has it been tied to a grab rail		
Can toilet paper / tissue be accessed with one hand		
Is there good colour contrast between fittings and wall finish		
Are two shelves (one colostomy) fitted		



Crown Copyright acknowledged

